



EC CERTIFICATE

Fire Resistance of Lift Landing Doors

CERTIFICATE NR: LF-613612018

EMAY METAL KALIP MÜHENDİSLİK SAN.ve TİC.LTD.ŞTİ.

Beşevler Küçük Sanayi Sitesi 24 Blok No:21/22 Beşevler/BURSA - TURKEY

Product Description : Fire resistant side opening (telescopic) lift landing door.

Product Type :  **emay** - T2K

(1000 x 2000) mm (width x height)

Basis of the certificate: 95/16/EC Lift Directive, EN 81-58:2003

CLASSIFICATION : E 120 / EW 60

Test Report : RFTR12009 / EFECTIS ERA AVRASYA

Conclusion : Fire resistant central opening lift landing door meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.
Classification results are considered to be applicable to doors of size within the tolerance of $\pm 30\%$ width and $\pm 15\%$ height if all other constructional details being the same from those of type.

Date of issue: 15/05/2012

Director

SZUTEST
TECHNICAL INSPECTION
AND CERTIFICATION
SERVICES CO. LTD.

İnönü Mah. Kayışdağı Cad. No:148 Kat: 3-4
Ataşehir / İstanbul - Türkiye
Tel: +90 216 469 46 66 Faks: +90 216 469 46 67
e-mail: info@szutest.com.tr - www.szutest.com.tr